


Notice For User

- Please turn off power before install or change assembly parts.
- The input voltage and lamps should be matched, after connecting the power line, please make sure the wiring section is insulated.
- Make sure to remove or bypass the ballast in the fixtures before install the lamps.
- Suitable for damp locations. Do not use with dimmers.
- Suitable for use in enclosed luminaires, min. lamp compartment dimensions: 440*260*260MM.
- No-professionals, must not install and disassemble the lamps.





INSTALLATION GUIDE

Retrofit Lamps

CPS-RL

Notice For User

- Please turn off power before install or change assembly parts.

Replace CFL

Replace MHL / HPS

Ballast